

Exemption from provisions of Health and Safety at Work (Hazardous Substances) Regulations 2017

In accordance with section 220 of the Health and Safety at Work Act 2015 (the Act), I, Nicole Rosie, Chief Executive of WorkSafe New Zealand, exempts **Clelands Timber Ltd** from compliance with regulation 11.37 of the Health and Safety at Work (Hazardous Substances) Regulations 2017 for the building type and separation distance of its LOSP timber treatment plant building at 61 Katere Road New Plymouth.

I do so –

- being satisfied that:
 - a. the extent of the exemption is not broader than is reasonably necessary to address the matters that gave rise to it; and
 - b. the exemption is not inconsistent with the purpose of the Act; and
- subject to the conditions specified on the following page:

This exemption takes effect on **30 May 2018** and expires on **30 May 2023** unless it is replaced sooner or revoked.

Signed at Wellington this³⁰ day of^{May}..... 20.....¹⁸



Nicole Rosie
Chief Executive
WorkSafe New Zealand

Exemption Conditions

- a. Clelands Timber Ltd must comply with the conditions of SEP1631 issued by WorkSafe on 20 March with the following variation to condition 9:
 9. By 30 November 2018, Clelands Timber Ltd must:
 - Locate the tank fill point outside the building at least two metres from any opening into the building (see AS1940:2004), section 5.3.2(c)) and
 - Upgrade the fire rating of eastern wall of the treatment plant building to no less than -/240/60 FRR to a height of 5.1 metres.