

Notice of Exemption

In accordance with section 220 of the Health and Safety at Work Act 2015 (the Act), Elgas Limited is exempted from compliance with regulation 15.74(1) of the Health and Safety at Work (Hazardous Substances) Regulations 2017 (the HS Regulations) to permit the use of two tank wagon barrels identified, as X8705 and X8615, for holding LPG for the purposes of delivery by in-situ filling of cylinders at Elgas client sites.

Elgas Limited must –

- (1) ensure each tank barrel does not exceed 10,160 litres water capacity; and
- (2) hold a copy of this exemption in the cab of the tank wagon.

This exemption takes effect on 1 January 2024 and expires on 1 January 2029 unless it is replaced sooner or revoked, as specified in the *Gazette* notice required by section 221 HSWA.

This exemption is given the reference HS2208.

Signed at Wellington this 14th day of August 2023



Phil Parkes
Chief Executive
WorkSafe New Zealand